

Receiver list_Base Model
(WPP Lozenetz – 80 WTG)

No.	Receiver name	Coordinates X Y in meter	Building side	Floor	Limit				Level				Conflict			
					Day	Evening	Night	Lden	Day	Evening	Night	Lden	Day	Evening	Night	Lden
					dB(A)				dB(A)				dB			
1	BiS_01	558548.0 4853228	-	GF	55	50	45	-	34.7	34.9	35.0	41.2	-	-	-	-
				1.FI	55	50	45	-	34.9	35.0	35.1	41.4	-	-	-	-
				2.FI	55	50	45	-	35.6	35.7	35.8	42.2	-	-	-	-
2	KrU_01	561290.3 4852100	-	GF	55	50	45	-	39.5	39.5	39.6	46.1	-	-	-	-
				1.FI	55	50	45	-	39.7	39.7	39.7	46.1	-	-	-	-
				2.FI	55	50	45	-	40.3	40.3	40.4	46.8	-	-	-	-
3	KrU_02	561188.0 4851594	-	GF	55	50	45	-	38.5	38.5	38.7	45.2	-	-	-	-
				1.FI	55	50	45	-	38.7	38.7	38.8	45.2	-	-	-	-
				2.FI	55	50	45	-	39.4	39.5	39.5	45.9	-	-	-	-
4	KrU_03	560742.7 4851337	-	GF	55	50	45	-	37.5	37.5	37.7	44.1	-	-	-	-
				1.FI	55	50	45	-	37.6	37.6	37.7	44.1	-	-	-	-
				2.FI	55	50	45	-	38.3	38.4	38.5	44.8	-	-	-	-
5	KrU_04	560208.6 4851510	-	GF	55	50	45	-	37.1	37.2	37.4	43.7	-	-	-	-
				1.FI	55	50	45	-	37.2	37.3	37.4	43.7	-	-	-	-
				2.FI	55	50	45	-	38.0	38.0	38.1	44.5	-	-	-	-
6	LoZ_01	558288.6 4846317	-	GF	55	50	45	-	41.0	41.0	41.1	47.5	-	-	-	-
				1.FI	55	50	45	-	41.0	41.0	41.1	47.5	-	-	-	-
				2.FI	55	50	45	-	41.7	41.7	41.8	48.1	-	-	-	-
7	LoZ_02	558502.0 4845704	-	GF	55	50	45	-	40.4	40.4	40.5	46.9	-	-	-	-
				1.FI	55	50	45	-	40.5	40.5	40.6	46.9	-	-	-	-
				2.FI	55	50	45	-	41.2	41.2	41.3	47.6	-	-	-	-
8	LoZ_03	558637.1 4844763	-	GF	55	50	45	-	39.8	39.8	39.9	46.4	-	-	-	-
				1.FI	55	50	45	-	40.0	40.0	40.0	46.4	-	-	-	-
				2.FI	55	50	45	-	40.7	40.7	40.8	47.1	-	-	-	-
9	PoL_01	563302.5 4854099	-	GF	55	50	45	-	31.4	31.4	31.5	37.9	-	-	-	-
				1.FI	55	50	45	-	31.7	31.8	31.9	37.9	-	-	-	-
				2.FI	55	50	45	-	32.1	32.2	32.3	38.6	-	-	-	-
10	SeV_01	555812.5 4850141	-	GF	55	50	45	-	38.6	38.6	38.8	45.3	-	-	-	-
				1.FI	55	50	45	-	38.8	38.8	38.9	45.3	-	-	-	-
				2.FI	55	50	45	-	39.5	39.5	39.6	45.9	-	-	-	-
11	SeV_02	556085.9 4850025	-	GF	55	50	45	-	39.0	39.0	39.1	45.5	-	-	-	-
				1.FI	55	50	45	-	39.1	39.1	39.1	45.5	-	-	-	-
				2.FI	55	50	45	-	39.8	39.8	39.8	46.2	-	-	-	-
12	SeV_03	556242.4 4849767	-	GF	55	50	45	-	39.0	39.0	39.1	45.5	-	-	-	-
				1.FI	55	50	45	-	39.1	39.1	39.1	45.5	-	-	-	-
				2.FI	55	50	45	-	39.8	39.8	39.8	46.2	-	-	-	-
13	SvO_01	565459.7 4845135	-	GF	55	50	45	-	36.1	36.1	36.3	42.8	-	-	-	-
				1.FI	55	50	45	-	36.3	36.3	36.4	42.8	-	-	-	-
				2.FI	55	50	45	-	37.0	37.1	37.1	43.5	-	-	-	-
14	SvO_02	565239.0 4844624	-	GF	55	50	45	-	34.0	34.0	34.1	40.6	-	-	-	-
				1.FI	55	50	45	-	34.0	34.1	34.2	40.6	-	-	-	-
				2.FI	55	50	45	-	34.8	34.9	35.0	41.3	-	-	-	-
15	SvO_03	565318.3 4844155	-	GF	55	50	45	-	31.4	31.7	32.0	38.4	-	-	-	-
				1.FI	55	50	45	-	31.7	31.9	32.1	38.4	-	-	-	-
				2.FI	55	50	45	-	32.5	32.7	32.9	39.2	-	-	-	-
16	ZaG_01	562667.2 4848076	-	GF	55	50	45	-	40.1	40.1	40.3	46.8	-	-	-	-
				1.FI	55	50	45	-	40.3	40.3	40.4	46.8	-	-	-	-
				2.FI	55	50	45	-	41.0	41.1	41.1	47.5	-	-	-	-
17	ZaG_02	562998.7 4847975	-	GF	55	50	45	-	40.2	40.3	40.5	47.0	-	-	-	-
				1.FI	55	50	45	-	40.5	40.6	40.6	47.0	-	-	-	-
				2.FI	55	50	45	-	41.2	41.3	41.3	47.7	-	-	-	-
18	ZeM_01	562702.4 4850130	-	GF	55	50	45	-	40.2	40.4	40.4	46.9	-	-	-	-
				1.FI	55	50	45	-	40.4	40.5	40.5	46.9	-	-	-	-
				2.FI	55	50	45	-	41.1	41.1	41.2	47.6	-	-	-	-
19	ZeM_02	562389.7 4849596	-	GF	55	50	45	-	39.5	39.5	39.7	46.3	-	-	-	-
				1.FI	55	50	45	-	39.8	39.8	39.9	46.3	-	-	-	-
				2.FI	55	50	45	-	40.5	40.5	40.6	47.0	-	-	-	-
20	ZeM_03	562849.8 4849882	-	GF	55	50	45	-	40.0	40.0	40.1	46.7	-	-	-	-
				1.FI	55	50	45	-	40.2	40.2	40.3	46.7	-	-	-	-
				2.FI	55	50	45	-	40.9	40.9	41.0	47.3	-	-	-	-